



# OMEGALAB TESTING SERVICES PRIVATE LIMITED

ESTD. 1999

A Govt. Regd. Test House



Management System :

As per ISO/IEC 17025:2017

CORPORATE IDENTITY NUMBER : U71200WB2023PTC262957

CORPORATE OFFICE :

256A, M. G. Road, Purbasan, Thakurpukur, Kolkata - 700063

LABORATORY 1 : 256A, M. G. Road, Purbasan, Thakurpukur, Kolkata - 700063

LABORATORY 2 : 996, M. G. Road, Purbasan, Thakurpukur, Kolkata - 700063

Contacts : (033) 2497 1903, M (+91) 9830020628 / M (+91) 9432219707

E-mail : omegalabinfo98@gmail.com

www.omegalabtesting.co.in

## TEST REPORT

Job ID No.: OTSK/27/MY/2025/15 -01 (Physical)		Date: 06.06.2025	Page: 1 of 1
#Ref. No. :	E-mail Date: 24.05.2025	#Product Specification :	IS:15388-2003, Reaf:2022
#Issued To :	M/s- Whitespice Chemicals India Pvt. Ltd. 41A, AJC Bose Road, 2 <sup>nd</sup> Floor, Suite-218, Kolkata-700017	#Test Specification :	IS: 1727:1967 Reaf:2018
#Description of Sample(s) :	Micro Silica (Silica Fume With Ultratech OPC 43 Cement) sample for the following tests. Grade: 85+	#Seal / Stamp / Mark (if any) :	Sealed
Subject :	Testing of Micro Silica.		
#Test Parameters :	Over Size Percent Retained on 45 micron IS Sieve & variation from average, Compressive strength, Specific Gravity & Consistency	Sample received on :	27.05.2025
		Sample tested on :	29.05.2025 to 05.06.2025

This is to certify that the above sample (S) has/have been tested with the following results:

### PHYSICAL PROPERTIES

#### I. Building Infrastructure & Construction Materials:

- Silica Fume:

Room Temperature: 27.3°C

Characteristics	Findings	Req. as per IS:15388-2003, Reaf:2022
1. Over Size Percent Retained on 45 micron IS Sieve (%)	2.0	10.00 Max
2. Over Size Percent Retained on 45 micron IS Sieve, variation from average (%)	0.51	5.00 Max
3. Compressive strength at 7 days as percent of control sample, (%)	119.0	85.00 Min
4. Specific Gravity	2.18	Not specified
5. Consistency (%)	34.5	Not specified

Remarks: The above submitted sample was duly tested as per relevant specification.

RBa

Prepared by

◆◆◆◆ End of report ◆◆◆◆

For OMEGALAB TESTING SERVICES PVT. LTD.

*[Signature]*

S. K. CHATTERJEE  
DEPUTY TECHNICAL MANAGER  
(MECH.: BM/SR, NDT: BM-RCS)  
(AUTHORISED SIGNATORY)

Note :

- \* "\*" denote the information are supplied by customer.
- \* Decision Rule applied as per OTSPL/QMSP-10 (wherever applicable)
- \* The test report relates to the Sample(s) submitted by Customer.
- \* Liability for return of sample(s) ceases after fifteen days unless advised by concerned authority.
- \* The reproduction of the report except in full is invalid without written approval of the laboratory management.
- \* The test results referred in test report are based on observations & measurements under the stated environmental conditions.