



# OMEGALAB TESTING SERVICES PRIVATE LIMITED

ESTD. 1999

A Govt. Regd. Test House



Laboratory Accredited By :

NABL, A constituent Board of Quality Council  
of India, Govt. of India

Management System : As per ISO/IEC 17025:2017

CORPORATE IDENTITY NUMBER : U71200WB2023PTC262957

CORPORATE OFFICE :

256A, M. G. Road, Purbasan, Thakurpukur, Kolkata - 700063

LABORATORY : 256A, M. G. Road, Purbasan, Thakurpukur, Kolkata - 700063

Contacts : (033) 2497 1903, M (+91) 9830020628 / M (+91) 9432219707

E-mail : omegalabinfo98@gmail.com



TC-11935

ULR No.: TC1193525000001260F

Format No. OTSPL/QR/1078

## TEST REPORT

Job ID No.: OTSK/27/MY/2025/15 -01 (Chemical-01)

Date: 06.06.2025

Page: 1 of 1

#Ref. No. : E-mail Date: 24.05.2025	#Product Specification : IS:15388-2003, Reaf:2022
#Issued To : M/s- Whitespice Chemicals India Pvt. Ltd. 41A, AJC Bose Road, 2 <sup>nd</sup> Floor, Suite-218, Kolkata-700017	#Test Specification : Tabulated Below
#Description of Sample(s) : Micro Silica sample for the following tests. Grade: 85+	#Seal / Stamp / Mark (if any) : Sealed
Subject : Testing of Micro Silica.	
#Test Parameters : Silica, Moisture Content, Loss on Ignition, Na <sub>2</sub> O, K <sub>2</sub> O & Alkalis.	Sample received on : 27.05.2025 Sample tested on : 27.05.2025 to 04.06.2025

This is to certify that the above sample (S) has/have been tested with the following results:

## CHEMICAL ANALYSIS

### I. Building Material:

#### • Pozzolan materials:

Characteristics	Findings	Req. as per IS:15388-2003, Reaf:2022	Test Method
1. Silica as SiO <sub>2</sub> , (%)	87.64	85.00 Min	IS:1727:1967 Reaf:2018
2. Moisture Content, (%)	0.49	3.00 Max	IS:15388-2003, Reaf:2022
3. Loss on Ignition, (%)	3.8	4.00 Max	IS:1727:1967 Reaf:2018
4. Sodium Oxide as Na <sub>2</sub> O, (%)	Awaited	Not Specified	IS:15388-2003, Reaf:2022
5. Potassium Oxide as K <sub>2</sub> O, (%)	Awaited	Not Specified	
6. Alkalis as Na <sub>2</sub> O, (%)	Awaited	1.5 Max.	

Remarks: The above submitted sample was duly tested as per relevant specification.

Prepared by

◆◆◆ End of report ◆◆◆

For OMEGALAB TESTING SERVICES PVT. LTD.

I. MUKHERJEE (BANERJEE)  
DEPUTY QUALITY MANAGER  
(AUTHORISED SIGNATORY-CHEM.)

Note :

- \* "\*" denote the information are supplied by customer.
- \* Decision Rule applied as per OTSPL/QMSP-10 (wherever applicable)
- \* The test report relates to the Sample(s) submitted by Customer.
- \* Liability for return of sample(s) ceases after fifteen days unless adviced by concerned authority.
- \* The reproduction of the report except in full is invalid without written approval of the laboratory management.
- \* The test results referred in test report are based on observations & measurements under the stated environmental conditions.